

Snowy Monaro Regional Council
Monthly Effluent Discharge Test Results
 Adaminaby STP - EPA Licence: 450
 EPA Point 2 - Final Discharge Effluent Sampling

<i>DATE</i>	<i>pH</i>	<i>TSS</i> (mg/l)	<i>Oil & Grease</i> (mg/l)	<i>BOD</i> (mg/l)	<i>Ammonia</i> (mg/l)	<i>Total N</i> (mg/l) N	<i>Total P</i> (mg/l) P	<i>Aluminium dissolved</i> (mg/L)	<i>Aluminium total</i> (mg/L)	<i>Faecal Coliforms</i> (CFU/100ml)	<i>Entered by</i>
30-Oct-24	7.29	5.00	0.50	2.00	0.20	2.82	0.23	0.05	0.72	0.50	EA
17-Dec-24	7.38	7.00	0.50	1.00	0.05	2.15	0.10	0.05	0.86	0.50	EA
22-Jan-25	7.53	9.00	0.50	1.00	0.05	2.38	0.14	0.10	1.50	1.00	EA
19-Feb-25	7.75	7.00	0.50	1.00	0.05	1.66	0.06	0.04	0.92	1.00	EA
Lowest	7.29	5.00	0.50	1.00	0.05	1.66	0.06	0.04	0.72	0.50	
Mean	7.49	7.00	0.50	1.25	0.09	2.25	0.13	0.06	1.00	0.75	
Highest	7.75	9.00	0.50	2.00	0.20	2.82	0.23	0.10	1.50	1.00	
90%ile		8.40	0.50	1.70	0.16	2.69	0.20	0.09	1.33	1.00	
100%ile											
Licence Target											
90%	6.5-8.5	15	2	10	2	10	0.5			200	
100%											
Summary of Non-Compliance											
Date	Summary										