

Snowy Monaro Regional Council
Monthly Effluent Discharge Test Results
 Berridale STP - EPA Licence: 456
 EPA Point 1 (Discharge)

<i>DATE</i>	<i>pH</i>	<i>BOD</i> <i>(mg/l)</i>	<i>Oil & Grease</i> <i>(mg/l)</i>	<i>TSS</i> <i>(mg/l)</i>	<i>Faecal C</i> <i>CFU/100ml</i>	<i>Ammonia</i> <i>(mg/l) N</i>	<i>Total P</i> <i>(mg/l) P</i>	<i>Total N</i> <i>TKN+NOX</i>	<i>Entered</i> <i>by</i>
02-Oct-24	7.40	7.00	0.50	8.00	30.00	0.20	0.44	4.10	EA
30-Oct-24	6.92	10.00	0.50	29.00	34.00	1.00	1.11	5.59	EA
27-Nov-24	7.70	5.00	0.50	25.00	6.00	0.40	0.34	5.21	EA
18-Dec-24	7.30	3.00	0.50	23.00	6.00	0.40	0.66	3.84	EA
22-Jan-25	7.25	4.00	0.50	12.00	2.00	0.60	0.35	7.63	EA
19-Feb-25	7.18	1.00	0.50	7.00	1.00	0.20	0.11	6.19	EA
Lowest									
Mean									
Highest									
90%ile		8.50	0.50	27.00		0.80	0.89	6.91	
100%ile	7.70	10.00	0.50	29.00	34.00	FALSE	1.11	7.63	
Licence Target									
90%		10	2	15		1	9	10	
100%	6.5-8.5	20	10	30	100	10	10	25	
Summary of Non-Compliance									
Date	Summary								