

**Snowy Monaro Regional Council**  
**Monthly Effluent Discharge Test Results**  
 Jindabyne STP - EPA Licence: 773  
 EPA Point 1 (Discharge)

DATE	pH pH	BOD (mg/l)	Oil & Grease (mg/l)	TSS (mg/l)	Faecal C (CFU/100ml)	Ammonia (mg/l) N	Total P (mg/l) P	Total N TKN+NOX	Dissolved Alluminium mg/L	Total Alluminium mg/L	Entered by
19-Feb-25	7.82	1.00	0.50	8.00	26.0	1.00	0.39	2.57	0.10	0.29	EA
Lowest	7.82	1.00	0.50	8.00	26.00	1.00	0.39	2.57	0.10	0.29	
Mean	7.82	1.00	0.50	8.00	26.00	1.00	0.39	2.57	0.10	0.29	
Highest	7.82	1.00	0.50	8.00	26.00	1.00	0.39	2.57	0.10	0.29	
90%ile	7.82	1.00	0.50	8.00		1.00	0.39	2.57			
100%ile		1.00	0.50	8.00	26.00	1.00	0.39	2.57			
<b>Licence Target</b>											
90%	6.5-8.5	10	2	15	200	2	0.3	10			
100%		15	10	20	600	5	1	15			
<b>Summary of Exceedances</b>											
*The licensee is not taken to have exceeded a quality limit specified in this licence for BOD, TSS or pH if chlorophyll-a is 100µg/L or more at EPA											
Date	Summary										
19-Feb-25	Phosphorous exceeded the 90th percentile limit. Exceedance is likely due to environmental conditions. Warmer surface water is mixing phosphorous in the sediment.										