

**Snowy Monaro Regional Council**  
**Monthly Effluent Discharge Test Results**  
 Berridale STP - EPA Licence: 456  
 EPA Point 1 (Discharge)

<i>DATE</i>	<i>pH</i>	<i>BOD</i> <i>(mg/l)</i>	<i>Oil &amp; Grease</i> <i>(mg/l)</i>	<i>TSS</i> <i>(mg/l)</i>	<i>Faecal C</i> <i>(CFU/100ml)</i>	<i>Ammonia</i> <i>(mg/l) N</i>	<i>Total P</i> <i>(mg/l) P</i>	<i>Total N</i> <i>TKN+NOX</i>
04-Oct-23	7.57	1.00	0.50	6.00	1.00	0.05	0.87	6.70
01-Nov-23	7.84	3.00	0.50	9.00	22.00	0.30	0.25	3.92
29-Nov-23	7.71	3.00	0.50	10.00	72.00	0.70	1.44	4.00
27-Dec-23	7.31	1.00	0.50	8.00	280.00	0.60	1.44	7.02
24-Jan-24	7.88	1.00	0.50	3.00	2.00	0.05	3.48	5.68
21-Feb-24	7.92	1.00	0.50	8.00	21200.00	0.05	3.85	4.00
20-Mar-24	7.63	4.00	0.50	12.00	10.00	0.10	3.21	3.37
17-Apr-24	7.71	1.00	0.50	4.00	1.00	0.05	3.87	3.77
15-May-24	7.68	1.00	0.50	1.00	1.00	0.05	0.18	3.81
12-Jun-24	7.30	1.00	0.50	4.00	1.00	0.30	0.30	8.25
11-Jul-24	7.18	1.00	0.50	7.00	10.00	0.30	0.39	10.00
07-Aug-24	7.49	1.00	0.50	4.00	20.00	0.60	0.30	7.95
04-Sep-24	7.04	2.00	0.50	4.00	12.00	0.40	0.42	6.80
Lowest	7.04	1.00	0.50	1.00	1.00	0.05	0.18	3.37
Mean	7.56	1.62	0.50	6.15	1664.00	0.27	1.54	5.79
Highest	7.92	4.00	0.50	12.00	21200.00	0.70	3.87	10.00
90%ile		3.30	0.50	10.60		0.63	3.86	6.80
100%ile	7.92	4.00	0.50	12.00	21200.00	0.70	3.87	10.00